

REGIONAL WATER TESTING LAB, SANGRUR

Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtlsangrur@gmail.com

To,

Shri Surajkund Sarvhitkari Vidya Mandir
Khadial Road, Sunam


No.: RWTL/SNG/2627/00212 Dated : 25/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SVM/2026-2027 Dated: 23/05/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 23/05/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Sangrur

D/A : Test Report



**Authorized Signatory
For, Regional Water Testing Lab
Sangrur**

TEST REPORT


Name & Address of Customer : Shri Surajkund Sarvhitkari Vidya Mandir Khadial Road,Sunam		Customer Reference No.	No : SVM/2026-2027 Dated : 23/05/2026
		Sample Submitted by	
		Date of Sample Receipt	23/05/2026
		Analysis Starting Date	23/05/2026
		Analysis completion Date	25/05/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC179482600000022F	Sample Type :	Treated Water
Test Report No.:	RWTL/SNG/2627/00212	Date of Issue :	25/05/2026
Registration no.:	RWTL/SNG/REG2627/00854	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Sample No.1 / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Sunam	District :	Sangrur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.96	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	AGREEABLE	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	109	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	T. Alkalinity(CaCO ₃)	52	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	T. Hardness(CaCO ₃)	28	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
8	Calcium(Ca)	8	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
9	Magnesium(Mg)	BDL	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride(Cl)	8	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25 $\pm$ 5°C and Humidity condition limit:50 $\pm$ 20%

Reviewed and Approved By



Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Sangrur

----- End of the Test Report -----